

BASIS FOR VALENCIA

VALENCIA VS VANCOUVER

NOMINAL ELECTRICAL LOAD TABLE

AREA SYSTEM	RF	CONV	NC MAGNETS	WATER SYSTEMS	CYRO	EMER	TOTAL (by Area)	NOTES
SOURCES e-	1.05	1.19	0.57	1.27	0.00	0.06	4.13	Valencia
	Not Included	1.50			0.00	Not Included	1.50	Vancouver
SOURCES e+	4.11	7.32	6.52	1.27	0.00	0.21	19.43	Valencia
	Not Included	1.50			0.00	Not Included	1.50	Vancouver
DR	14.00	1.71	6.78	0.66	2.56	0.23	25.95	Valencia
	14.00	6.00			5.40	6.20	31.60	Vancouver
RTML	8.40	3.78	3.22	1.34	2.78	0.15	19.67	Valencia
	8.00	6.00			0.00	3.90	17.90	Vancouver
MAIN LINAC	86.47	15.43	1.41	9.86	32.20	0.40	145.77	Valencia
	93.00	63.70			68.80	3.60	229.10	Vancouver
BDS	0.00	1.11	18.48	3.51	0.24	0.20	23.54	Valencia
	Not Included	71.40			0.00	2.20	73.60	Vancouver
DUMPS	0.00	3.83	0.00	0.00	0.00	0.12	3.95	Valencia
	0.00	3.20			0.00	0.00	3.20	Vancouver
TOTAL (by System)	114.0	34.4	37.0	17.9	37.8	1.4	242.4	Valencia
		89.3						
TOTAL (by System)	115.0	153.3			74.2	15.9	358.4	Vancouver
CHANGE	-1.0	-64.0			-36.4	-14.5	-116.0	

MW **242.4** Valencia
MW **358.4** Vancouver